



STATE OF CONNECTICUT

DEPARTMENT OF PUBLIC HEALTH
ENVIRONMENTAL HEALTH SECTION

October 25, 2007

Tony Brockelman
Lijoma Wholesalers, LLC
25 Cross Street
P.O. Box 1112
Torrington, CT 06790

RE: Geo Fabrics GF 150 Filter Fabric

Dear Mr. Brockelman:

This Department reviewed the technical support documentation you submitted on the leaching system filter fabric designated as GF 150, which is manufactured by Geo Fabrics, LLC. You've indicated that Lijoma Wholesalers plans on distributing the fabric for subsurface sewage disposal system installations. The GF 150 fabric is a non-woven fabric, and the minimum average roll values meet the required criteria for unit weight, permittivity, and trapezoidal tear strength included in Technical Standards' Section VIII A. The fabric is stamped with the designation GF 150.

The Geo Fabric, LLC GF 150 filter fabric meets the Technical Standards' requirements for filter fabric used for covering leaching systems. The fabric has been added to the list (attached) of approved fabrics. Please feel free to reproduce this letter in its entirety as a means of notifying local health officials, professional engineers, installers and distributors, of this Department's approval. As with any product approval, this letter should not be considered an endorsement of the product.

Sincerely,

Robert W. Scully
Supervising Sanitary Engineer
Environmental Engineering Program

cc: Gary Zinn
Geo Fabrics, LLC
P.O. Box 46
Enigma, GA 31749



*Phone: (860) 509-7296, Fax: (860) 509-7295
Telephone Device for the Deaf (860) 509-7191
410 Capitol Avenue - MS #51SEW
P.O. Box 340308 Hartford, CT 06134
An Equal Opportunity Employer*